



Central Energy Audits, LLC
13408 E Meadow DR.
Peculiar, MO. 64078
(816) 645-6140

Date: February 11, 2019

To: Extreme Panel Technologies, Inc.
475 E 4th St. North
Cottonwood MN. 56229

RE: HERS Rating/Energy Audit for Weston, Missouri

Dear Extreme Panel Technologies,

We wanted to take the opportunity to discuss a recent inspection/test for a home in Weston Missouri. This was our first encounter with the SIPs manufacturing technique, and have to say, we were quite impressed. Furthermore, after the final air-sealing was completed, the building scored a **431 cfm** at 50 pascals of pressure on the blower door test. This is the lowest score our company has ever seen – especially with this being such a large building of **6670 square feet** of conditioned space. Even in our ENERGY STAR rated homes, we've only tested 700 cfm at best. The final HERS score came out far below the national average for new buildings, and could have easily qualified for the EPA's ENERGY STAR program.

In following the specified installation procedure and proper air-sealing, your SIPs panels have created the most energy efficient and well-constructed building envelope CEA has come across to date. My company simply wanted to express our admiration to the quality of materials and care placed into this project, and hope that you plan to continue promoting this innovative methodology to builders.

If you have any questions about our findings, please feel free to contact us. Thank you,

Krissa Albert

A handwritten signature in black ink that reads "Krissa Albert". The signature is written in a cursive, flowing style.

CEA Partner and Certified HERS Rater # 9501914
EPA certified ENERGY STAR Rater, RTIN: 9501914
Central Energy Audits, LLC
816.645.6140
info@centralenergyaudits.com