



Central Energy Audits, LLC
13408 E Meadow DR.
Peculiar, MO. 64078
(816) 645-6140

Date: January 31st, 2019

To: Teresa Lopez
Green Energy Money

RE: H.E.R.S. Rating/Energy Audits for 29345 Countryside Rd. Weston, Missouri 66007

Dear Ms. Lopez,

We wanted to thank you for giving us the opportunity to inspect/test the Weston home for Paul and Jennifer Edmonds. I have to say, we were quite impressed with the SIPS manufacturing technique. Furthermore, after the final air-sealing was completed, the building scored a **431 cfm** at 50 pascals of pressure. This is the lowest score I have ever seen – especially with this being such a large building. Even in our ENERGY STAR rated homes, we've only tested 700 cfm at best. Your final HERS score came out to a **46**. This is far below the national average for new buildings, and could have easily qualified for the EPA's ENERGY STAR program.

This was by far the most energy efficient and well-constructed building we have come across as of yet. My company simply wanted to express our admiration to the quality of materials and care placed into this project, and hope that you plan to continue with this innovative methodology.

If you have any questions about your results, please feel free to contact us. Thank you,

Krissa Albert

A handwritten signature in black ink that reads "Krissa Albert". The signature is written in a cursive, flowing style.

DoE certified HERS Rater # 9501914
EPA certified ENERGY STAR Rater, RTIN: 9501914
Central Energy Audits, LLC
816.645.6140
info@centralenergyaudits.com