

Home Energy Rating Certificate

Final Report

Rating Date: 2021-12-06

Registry ID: 257825888

Ekotrope ID: mvom60jL

HERS® Index Score:

44

Your home's HERS score is a relative performance score. The lower the number, the more energy efficient the home. To learn more, visit www.hersindex.com

Annual Savings

\$1,134

*Relative to an average U.S. home

Home:

4253 Prices Fork Rd Unit 190-201
Blacksburg, VA 24060


Builder:

Taylor Hall Construction

Your Home's Estimated Energy Use:

	Use [MBtu]	Annual Cost
Heating	1.9	\$63
Cooling	0.7	\$24
Hot Water	6.4	\$213
Lights/Appliances	13.9	\$396
Service Charges		\$211
Generation (e.g. Solar)	0.0	\$0
Total:	22.9	\$908

This home meets or exceeds the criteria of the following:



Home Feature Summary:

Home Type:	Apartment, end unit
Model:	B
Community:	N/A
Conditioned Floor Area:	1,089 ft ²
Number of Bedrooms:	2
Primary Heating System:	Air Source Heat Pump • Electric • 12.1 HSPF
Primary Cooling System:	Air Source Heat Pump • Electric • 18 SEER
Primary Water Heating:	Residential Water Heater • Electric • 0.93 UEF
House Tightness:	462.9 CFM50 (2.53 ACH50)
Ventilation:	33 CFM • 23 Watts
Duct Leakage to Outside:	31 CFM @ 25Pa (2.85 / 100 ft ²)
Above Grade Walls:	R-24
Ceiling:	Adiabatic, R-13
Window Type:	U-Value: 0.29, SHGC: 0.29
Foundation Walls:	N/A

Rating Completed by:

Energy Rater: Katy Maher

RESNET ID: 2430236

Rating Company: Viridiant

1431 W. Main Street, Richmond, VA 23220

Rating Provider: Viridiant

1431 W. Main Street, Richmond, VA 23220

Katy Maher

Katy Maher, Certified Energy Rater
Digitally signed: 12/22/21 at 10:49 AM

