

# HOME CERTIFIED TO MEET THE PROVISIONS OF THE 2012 INTERNATIONAL ENERGY CONSERVATION CODE

This home built at  
, Watertown, SD  
by Heilman Construction  
exceeds the minimum requirements for the 2012 International  
Energy Conservation Code

## Building Features

Ceiling Flat	NA	Duct	NA
Sealed Attic:	NA	Duct Leakage to Outside:	NA
Vaulted Ceiling	NA	Total Duct Leakage:	NA
Above Grade Walls	R-16.5	Infiltration:	Htg: 500 Clg: 500 CFM50
Foundation Walls	NA	Window	U-Value: 0.280, SHGC: 0.230
Exposed Floor	NA	Heating	Fuel-fired hydronic distribution, Natural gas, 98.0 AFUE.
Slab	None	Cooling	Air conditioner, Electric, 16.0 SEER.
		Water Heating	Integrated, Natural gas, 0.98 EF, 80.0 Gal.

The organization below certifies that the proposed building design described herein is consistent with the building plans, specifications, and other calculations submitted with the permit application. The proposed building has been designed to meet the 2012 IECC requirements in compliance with Chapter 4 based on Climate Zone 6A and with all mandatory requirements.

Name	Chris Johnson	Signature	
Organization	Johnson Environmental LLC	Date	November 09, 2015

The 2012 International Energy Conservation Code is a registered trademark of the International Code Council, Inc. ( "ICC").

No version of this software has been reviewed or approved by ICC or its affiliates.

REM/Rate - Residential Energy Analysis and Rating Software v14.6.1