


# Home Energy Rating Certificate



1115B 10th Street  
Storm Lake, IA 50588



5 Stars Plus  
Confirmed  
HERS Index: 63

## General Information

Conditioned Area	1500 sq. ft.	House Type	Townhouse, inside unit
Conditioned Volume	13226 cubic ft.	Foundation	Slab
Bedrooms	3		

## Mechanical Systems Features

Air-source heat pump:	Electric, Htg: 11.5 HSPF, Clg: 20.0 SEER.
Water Heating:	Conventional, Electric, 0.93 EF, 50.0 Gal.
Duct Leakage to Outside	36.00 CFM25.
Ventilation System	Exhaust Only: 55 cfm, 25.0 watts.
Programmable Thermostat	Heat=Yes; Cool=Yes

## Building Shell Features

Ceiling Flat	R-60.0	Slab	R-10.0 Edge, R-10.0 Under
Sealed Attic	NA	Exposed Floor	R-30.0
Vaulted Ceiling	NA	Window Type	U-Value: 0.350, SHGC: 0.350
Above Grade Walls	R-23.0	Infiltration Rate	Htg: 836 Clg: 836 CFM50
Foundation Walls	NA	Method	Blower door test

## Lights and Appliance Features

Percent Interior Lighting	100.00	Range/Oven Fuel	Electric
Percent Garage Lighting	100.00	Clothes Dryer Fuel	Electric
Refrigerator (kWh/yr)	345.00	Clothes Dryer EF	3.01
Dishwasher Energy Factor	0.00	Ceiling Fan (cfm/Watt)	0.00

Registry ID	700793789
Rating Number	
Certified Energy Rater	Pat O'Malley
Rating Date	9/14/15
Rating Ordered For	

## Estimated Annual Energy Cost

Use	MMBtu	Cost	Percent
Heating	18.3	\$490	33%
Cooling	1.4	\$38	3%
Hot Water	13.1	\$350	24%
Lights/Appliances	16.8	\$451	31%
Photovoltaics	-0.0	\$-0	-0%
Service Charges		\$144	10%
<b>Total</b>	<b>49.7</b>	<b>\$1473</b>	<b>100%</b>

## Criteria


This home meets or exceeds the minimum criteria for the following:  
EPA ENERGY STAR Version 2 Home  
EPA ENERGY STAR Version 2.5 Home  
2006 International Energy Conservation Code  
2009 International Energy Conservation Code

Building Knowledge, Inc.  
PO Box 1376  
Burnsville, MN 55337  
952-944-5605  
[www.buildingknowledge.com](http://www.buildingknowledge.com)

**REM/Rate - Residential Energy Analysis and Rating Software v14.5.1**

This information does not constitute any warranty of energy cost or savings. © 1985-2014 Architectural Energy Corporation, Boulder, Colorado.  
The Home Energy Rating Standard Disclosure for this home is available from the rating provider.


# HERS PERFORMANCE




# ENERGY RATING CERTIFICATE

**BUILDING  
KNOWLEDGE**

**Estimated Annual Energy Cost**



**Estimated Annual Energy Consumption**



Address 1115B 10th Street  
Storm Lake, IA 50588

House Type Townhouse, inside unit

Cond. Area 1500 sq. ft.

Rating No.

Issue Date October 21, 2015

Certification Verified

Annual Estimates\*

Electric(kWh): 14550

CO2 emissions(Tons): 12

Annual Savings\*\*: \$1259

\* Based on standard operating conditions

\*\* Based on a HERS 130 Index Home

Building Knowledge, Inc.

PO Box 1376

Certified Rater Pat O'Malley

Rater ID 9377462

Registry ID 700793789

Rating Date 9/14/15

**REM/Rate - Residential Energy Analysis and Rating Software v14.5.1**

This information does not constitute any warranty of energy cost or savings. © 1985-2014 Architectural Energy Corporation, Boulder, Colorado.  
The Home Energy Rating Standard Disclosure for this home is available from the rating provider.